



Proposed Code Change

State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 1/7/10

Code 46.3.3-09R

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

Code Title International Residential Code		Edition 2009
Section number and title R317.3.5 Flashing, fasteners in direct contact with treated wood. (NEW SECTION)		Page 66
Proponent Calvin Bolt Inspections and Testing	Title Owner	
Address 1310 Oriole Drive Warsaw, IN 46580		Phone 574-269-3507
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>Add a new Section 317.3.5 Flashing, Fasteners in direct contact with treated wood. Except for borate treated wood, aluminum fasteners, hardware, or flashing shall not be in direct contact with pressure preservative treated wood.</p>		
REASON AND FISCAL IMPACT		
<p>This proposal brings forward one sentence of an amendment from the 2005 Indiana Residential Code-R319.3. The WHOLE amendment was previously submitted in a proposal by Joe Heinsman, but he withdrew it.</p> <p>We need to at least have this one sentence included in the code, because aluminum will corrode when in direct contact with treated wood.</p> <p>No added cost. Just good information.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		